



产品认证证书

证书编号：CQC2019010304231443

申请人名称及地址

Tripus systems GmbH
Am hohen Rain 2, D-89347 Bubesheim

制造商名称及地址

Tripus Polska sp. z. o. o
ul. Zeromskiego 18, PL-56420 Bierutow

生产企业名称及地址

Tripus Polska sp. z. o. o (V056017)
ul. Zeromskiego 18, PL-56420 Bierutow

产品名称和系列、规格、型号

交流接触器

BR01;详见附件

产品标准和技术要求

GB/T14048.4-2010

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求，特发此证。

发证日期：2020年09月21日 有效期至：2024年09月23日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任：_____

陆楠



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0396899



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2019010304231443

NAME AND ADDRESS OF THE APPLICANT

Tripus systems GmbH
Am hohen Rain 2, D-89347 Bubesheim

NAME AND ADDRESS OF THE MANUFACTURER

Tripus Polska sp.z.o.o
ul. Zeromskiego 18, PL-56420 Bierutów

NAME AND ADDRESS OF THE FACTORY

Tripus Polska sp.z.o.o (V056017)
ul. Zeromskiego 18, PL-56420 Bierutów

PRODUCT NAME, MODEL AND SPECIFICATION

AC Contactor
BR01; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019.

Valid from: Sep.21,2020

Valid until: Sep.23,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0396899



产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2019010304231443

纸号: 396899

BR01

Ui:400V;

Uimp:4kV;

AC-3: Ue/ Ie: 110V/13.5A , 230V/13.5A , 400V/9A;

Ith: 16A;

Us: 230V 50Hz, 400V 50Hz(不适应触头数 22), 110V 50Hz (120V 60Hz), 200V 60Hz, 230V 60Hz, 200V DC, 24V DC, 24V 50Hz;

极数: 2P , 3P;

配用的辅助触头: (本体)

1NO, 1NC, 2NC, 无;

Ith:NC/NO:10A/16A;

AC-15: Ue/ Ie:400V/6A

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书


附录

第 2 页 共 2 页

证书编号: CQC2019010304231443

纸号: 396899

型号解释:



触头数量:

40 = 主触头 3NO
+辅助触头 1NO
31 = 主触头 3NO
+辅助触头 1NC
30 = 主触头 3NO
+辅助触头 0NO
22 = 主触头 2NO
+辅助触头 2NC

线圈电压:

01 = 230V/50Hz
02 = 400V/50Hz (不适应触头数 22)
03 = 110V/50Hz - 120V/60Hz
04 = 200V/60Hz
05 = 230V/60Hz
06 = 200V DC
07 = 24V DC
08 = 24V/50Hz

线圈电压或特殊安装:

01 = 线圈电压 AC
03 = 线圈电压 DC
04 = 可安装在电路板

注: 此附录与证书同时使用时有效。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>